

EC Declaration of Conformity

The undersigned, representing the manufacturer

Rockwell Automation, Inc.
1201 South 2nd Street
Milwaukee, WI 53204
USA

*and the authorised representative established within the
Community*

Rockwell Automation European Headquarters SA/NV
Vorstlaan/Boulevard du Souverain 36 – BP 3A/B
B-1170 Brussels
Belgium

*herewith declare that the Products
Product identification (brand and
catalogue number/part number):*

Point Block Product Family
Allen-Bradley 1734D Series
(reference the attached list of catalogue numbers)

*are in conformity with the provisions of the following EC Directive(s) when installed in accordance with the
installation instructions contained in the product documentation:*

2006/95/EC	Low Voltage Directive (LVD)
2004/108/EC	EMC Directive

and that the standards and/or technical specifications referenced below have been applied as indicated:


EN 61131-2:2007	Programmable controllers - Part 2: Equipment requirements and tests (Clause 8: Zone A/B EMC and Clause 11: LVD)
EN 61326-1:2006	Electrical equipment for measurement, control and laboratory use - EMC requirements – Part 1: General requirements (Industrial)
EN 61000-6-4:2007	Electromagnetic Compatibility (EMC) - Part 6-4: Generic Standards - Emission Standard for Industrial Environments (Class A)
EN 61000-6-2:2005	Electromagnetic Compatibility (EMC) - Part 6-2: Generic Standards - Immunity for Industrial Environments

Year of CE Marking (Low Voltage Directive): 1999

Manufacturer: **Rockwell Automation** *Authorised Representative in the Community:*


Signature

Name: John R. Mowry
Position: Compliance Engineer
Date: 12-Dec-2008


Signature

Name: Viktor Schiffer
Position: Engineering Manager
Date: 15-Dec-2008

<i>Catalogue number</i>	<i>Series¹</i>	<i>Description</i>	<i>Directive²</i>	
			<i>EMC</i>	<i>LV D</i>
1734D-IA16		<i>16 Channel, 120Vac Input Screw Terminal Module</i>	YES	YES
1734D-IA16S		<i>16 Channel, 120Vac Input Spring Terminal Module</i>	YES	YES
1734D-IA8XOA8		<i>120Vac Input/120Vac Output Screw Terminal Module</i>	YES	YES
1734D-IA8XOA8S		<i>120Vac Input/120Vac Output Spring Terminal Module</i>	YES	YES
1734D-IA8XOW8		<i>120Vac Input/240Vac Relay Output Screw Terminal Module</i>	YES	YES
1734D-IA8XOW8S		<i>120Vac Input/240Vac Relay Output Spring Terminal Module</i>	YES	YES
1734D-IB16		<i>16 Channel, 24Vdc Sinking Input Screw Terminal Module</i>	YES	N/R
1734D-IB16S		<i>16 Channel, 24Vdc Sinking Input Spring Terminal Module</i>	YES	N/R
1734D-IB8XOB8E		<i>24Vdc Sinking Input/Protected Sourcing Output Screw Terminal Module</i>	YES	N/R
1734D-IB8XOB8ES		<i>24Vdc Sinking Input/Protected Sourcing Output Spring Terminal Mdl</i>	YES	N/R
1734D-IB8XOW8		<i>24Vdc Sinking Input/240Vac Relay Output Screw Terminal Module</i>	YES	YES
1734D-IB8XOW8S		<i>24Vdc Sinking Input/240Vac Relay Output Spring Terminal Module</i>	YES	YES

¹ Products of the series level shown, or higher, are certified to the directives noted. If no series number is given, then all series are covered.

² YES = Product is certified to this directive.

N/R = This directive is not required for this product (falls below applicable voltage levels).