

## EC Declaration of Conformity

The undersigned, representing the manufacturer

**Rockwell Automation, Inc.**  
1201 South 2<sup>nd</sup> Street  
Milwaukee, WI 53204  
U.S.A.

and the authorised representative established within the  
Community

**Rockwell Automation European Headquarters SA/NV**  
Vorstlaan/Boulevard du Souverain 36 – BP 3A/B  
B-1170 Brussels  
Belgium

herewith declare that the Products

**Compact Industrial Power Supplies**

Product identification (brand and  
catalogue number/part number):

**Allen-Bradley 1606-XLP Series**  
(see attached list of catalogue numbers)

---

are in conformity with the essential requirements of the following EC Directive(s) when installed in accordance with the installation instructions contained in the product documentation:

2006/95/EC Low Voltage Directive

2004/108/EC EMC Directive

---

and that the standards and/or technical specifications referenced below have been applied:

EN 60950-1:2006 Information technology equipment – Safety – Part 1: General requirements

EN 61204-3:2000 Low voltage power supplies, d.c. output – Part 3: Electromagnetic compatibility (EMC)

EN 61000-6-3:2007 Electromagnetic compatibility (EMC) – Part 6-3: Generic standards – Emission standard for residential, commercial and light-industrial environments


EN 61000-6-2:2005 Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity for industrial environments

---

Year of CE Marking (Low Voltage Directive): 2003


---

Manufacturer: Authorised Representative in the Community:



**Signature**

Name: Daniel L. Nachtigall  
Position: Supv – Product Certification Engineering  
Date: 05-May-2009



**Signature**

Name: Viktor Schiffer  
Position: Engineering Manager  
Date: 08-May-2009

<i>Catalogue number</i>	<i>Series <sup>1</sup></i>	<i>Description</i>
1606-XLPxxx	A	<i>Compact DC power supply per Nomenclature below</i>
1606-XLPRED	A	<i>Redundancy module</i>

1) All products of the indicated series and higher are covered.

**NOMENCLATURE:**

1606	-	XLP	100	D	R
1		2	3	4	5

1	Designates Bulletin Number 1606 – Industrial power supply
2	Designates Product Type XLP – Compact family
3	Designates Output Watts Any number between 25 and 100
4	Designates Output Voltage A – 5 Vdc B – 12 Vdc or 12 to 15 Vdc C – Dual +/- 12 and 15 Vdc D – 24 Vdc E – 24 to 28 Vdc F – 48 to 56 Vdc G – 36 to 43 Vdc
5	Designates Special Functions (may be multiple suffixes) Blank – None R – Redundancy module P – Power factor correction S – Special output signals L – Load sharing T – Remote shutdown X – Semi-regulated Z – Removable terminal block