

## ***EC Declaration of Conformity***

*The undersigned, representing the supplier*  
**Rockwell Automation, Inc.**  
**1201 South 2<sup>nd</sup> Street**  
**Milwaukee, WI 53204**  
**U.S.A.**

*and the authorised representative within the Community*  
**Rockwell Automation European Headquarters SA/NV**  
**Vorstlaan/Boulevard du Souverain 36 – BP 3A/B**  
**B-1170 Brussels**  
**Belgium**

*herewith declare that the Products*     ***IEC Circuit Breakers***  
*Product identification (brand and*     ***Allen-Bradley 1489-A Series and Accessories***  
*catalogue number/part number):*     *(see attached list of catalogue numbers)*

---

*are in conformity with the provisions of the following EC Directive(s) when installed in accordance with the installation instructions contained in the product documentation:*

2006/95/EC                                     *Low Voltage Directive*

---

*and that the standards and/or technical specifications referenced below have been applied:*

EN 60947-1:2004                             *Low-voltage switchgear and controlgear – Part 1: General rules*

EN 60947-2:2003                             *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*


EN 60947-5-1:2004                         *Low voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

---


*Year of CE Marking*   2006

---

*Supplier:*   *Authorised Representative in the Community:*



***Signature***  
*Name:*             Daniel L. Nachtigall  
*Position:*         Spv – Product Certification Engineering  
*Date:*             12-Jul-2008



***Signature***  
*Name:*             Viktor Schiffer  
*Position:*         Engineering Manager  
*Date:*             16-Jul-2008

Catalogue number	Series <sup>1</sup>	Description	Standard <sup>2</sup>		
			EN 60947-1	EN 60947-2	EN 60947-5-1
1489-Axxxx		IEC circuit breaker per Nomenclature	YES	YES	N/R
<b>Accessories</b>					
1489-AAHS3		Auxiliary switch	YES	N/R	YES
1489-AAHH3		Auxiliary switch	YES	N/R	YES
1489-ABH12		Auxiliary switch	YES	N/R	YES
1489-AASTA*		Shunt trip release	YES	YES	N/R

1) If no series number is given, then all series are covered.

2) YES = Product is certified to this standard.

N/R = This standard is not required for this product.

**NOMENCLATURE:**

1489-A	1	A	B	R
	1	2	3	4

1	Product Line 1489-A – IEC circuit breaker
2	Number of Poles 1 – 1 pole 2 – 2 pole 3 – 3 pole
3	Trip Curve C – Inductive D – Highly inductive
4	Current Rating 005 – 0.5 A                      060 – 6.0 A                      200 – 20.0 A 010 – 1.0 A                      070 – 7.0 A                      250 – 25.0 A 015 – 1.5 A                      080 – 8.0 A                      300 – 30.0 A 020 – 2.0 A                      100 – 10.0 A                      320 – 32.0 A 030 – 3.0 A                      130 – 13.0 A                      350 – 35.0 A 040 – 4.0 A                      150 – 15.0 A                      400 – 40.0 A 050 – 5.0 A                      160 – 16.0 A
5	Options R – Ring terminal connector