

EC Declaration of Conformity

The undersigned, representing the manufacturer

Rockwell Automation, Inc.
1201 South 2nd Street
Milwaukee, WI 53204
U.S.A.

*and the authorised representative established within the
Community*

Rockwell Automation European Headquarters SA/NV
Vorstlaan/Boulevard du Souverain 36 – BP 3A/B
B-1170 Brussels
Belgium

herewith declare that the Products

Powermonitor 3000 Power Meters

*Product identification (brand and
catalogue number/part number):*

Allen-Bradley 1404 Series
(reference the attached list of catalogue numbers)

*are in conformity with the essential requirements of the following EC Directive(s) when installed in accordance with
the installation instructions contained in the product documentation:*

2006/95/EC

Low Voltage Directive

2004/108/EC

Electromagnetic Compatibility (EMC) Directive

and that the standards and/or technical specifications referenced below have been applied:

EN 61010-1:2001

*Safety requirements for electrical equipment for measurement, control, and
laboratory use – Part 1: General requirements (LVD only)*

EN 61000-6-4:2001

*Electromagnetic compatibility (EMC) – Part 6-4: Generic standards –
Emission standard for industrial environments*

EN 61000-6-2:2001


*Electromagnetic compatibility (EMC) – Part 6-2: Generic standards –
Immunity for industrial environments*

Year of CE Marking (Low Voltage Directive):

2000


Manufacturer:

Authorised Representative in the Community:



Signature

Name: Daniel L. Nachtigall
Position: Supv – Product Certification Engineering
Date: 21-Feb-2009



Signature

Name: Viktor Schiffer
Position: Engineering Manager
Date: 04-Mar-2009

Catalogue number	Series ¹	Description	CE Mark ²	
			LVD	EMC
1404-x05A-x-xx	A, B	Power metering module per Nomenclature	Yes	Yes
1404-x05B-x-xx	A, B	Power metering module per Nomenclature	N/A	Yes
1404-DM		Display Module	N/A	N/A

- 1) If no series number is given, then all series are covered
 2) Yes = Product is certified to this directive
 N/A = This directive is not required for this product

NOMENCLATURE:

1404	-	M4	05	A	-	000	-	02	X
1		2	3	4		5		6	7

1	Designates Product Type 1404 – PowerMonitor 3000
2	Designates Master Module Type M4 – Standard metering module M5 – Standard metering module (upgradeable) M6 – Enhanced metering module M8 – Transient metering module
3	Designates Current Input Rating 05 – 5 A
4	Designates Power Supply Rating A – 120/240 V ac, 50/60 Hz or 125/250 V dc B – 24 V ac, 50/60 Hz or 18/50 V dc
5	Designates Communications Options 000 – None 232 – RS-232 DNT - DeviceNet RIO – Remote I/O ENT - Ethernet
6	Designates Accuracy Option Blank – Standard 02 – High accuracy
7	Designates Reconditioned Status Blank – Not reconditioned X – Reconditioned product