

# Certificate



Certificate no.

T 72032253 01

**License Holder:**

Rockwell Automation  
1201 South Second Street  
Milwaukee WI 53204  
USA

**Manufacturing Plant:**

Product Services & Mfg. Co.  
4530 W. Burnham Street  
Milwaukee WI 53219  
USA

Test report no.: USA-GG 02271813 002

Client Reference: Therese Klein

Tested to: EN 954-1:1996  
EN 60204-1:1997

Certified Product: Safety Isolation System

License Fee - Units

Model Designation: Allen-Bradley "ElectoGuard Safety Isolation System":

7

2031c-baaaei (Non-Combination System)  
2032c-baaaei-mmm (Fusible Disconnect System)  
2033c\_baaaei-mmm (Combination Thermal Magnetic Circuit Breaker System)  
2030-EUen (Expansion Module)  
2030-CHaaai (Control Module)  
2030-RSA (RLS Switch Assembly)  
2030-RLSeW or 2030-RLSeG (Remote Lockout Station)  
2030-Pe1201 or 2030-Pe1203 (Pneumatic Isolation Module)  
continued on page 2

7

Appendix: 1

Licensed Test mark:

Signatures

Date of Issue  
(day/mo/yr)  
16/12/2003



Stephan Schmitt  
President

Dipl.-Ing. M. Raap  
QA Certification Officer

# Certificate



Certificate no.

T 72032253 02

**License Holder:**

Rockwell Automation  
1201 South Second Street  
Milwaukee WI 53204  
USA

**Manufacturing Plant:**

Product Services & Mfg. Co.  
4530 W. Burnham Street  
Milwaukee WI 53219  
USA

Test report no.: USA-GG 02271813 002

Client Reference: Therese Klein

Tested to: EN 954-1:1996  
EN 60204-1:1997

Certified Product: Safety Isolation System

License Fee - Units

aaa=0023,0043,0085,0110,0180,0210,0300,0420,0630,0860,1200  
e=A,J,F,C,P,H,W; i=A-C,G,H,N,M; mm=23-76; n=B,D,K,J, blank

Rated Voltage: 3 AC 220/380-400/400-415/440/500/550V, 50Hz  
3 AC 208/240/480/600V, 60Hz

Rated Current: 23, 43, 85, 110, 180, 210, 300, 420, 630,  
860 or 1200A

Protection Class: I

continued on page 3

Licensed Test mark:



Signatures

Stephan Schmitt  
President

Dipl.-Ing. M. Raap  
QA Certification Officer

Date of Issue

(day/mo/yr)  
16/12/2003

# Certificate



Certificate no.

T 72032253 03

**License Holder:**

Rockwell Automation  
1201 South Second Street  
Milwaukee WI 53204  
USA

**Manufacturing Plant:**

Product Services & Mfg. Co.  
4530 W. Burnham Street  
Milwaukee WI 53219  
USA

Test report no.: USA-GG 02271813 002

Client Reference: Therese Klein

Tested to: EN 954-1:1996  
EN 60204-1:1997

Certified Product: Safety Isolation System

License Fee - Units

continued from page 2:

Special Remarks: Category 4 according to EN 954-1:1996 in performing a safety isolation on a connected drive system up to rated current. This equipment is intended for use as an additional isolating means on the load side of the required supply-disconnecting device and over current protection.

Licensed Test mark:



Signatures

Stephan Schmitt  
President

Dipl.-Ing. M. Raap  
QA Certification Officer

Date of Issue

(day/mo/yr)

16/12/2003