


ZERTIFIKAT CERTIFICATE

EC Type-Examination Certificate


Reg.-No.: 01/205/5088/10

Product tested	Safety-related programmable Logic Controller GuardLogix including Safe Function Blocks	Certificate holder	Rockwell Automation, Inc. 1201 South Second Street Milwaukee, WI 53204 USA
Type designation	GuardLogix Modules, as listed in the Safety Reference Manual, Publication No. 1756-RM093F. For certified HW and SW versions see actual Revision Release List.	Manufacturer	see certificate holder
Codes and standards forming the basis of testing	IEC 61508 Parts 1-7:1998 / 2000 EN 62061:2005 EN ISO 13849-1:2008 + AC:2009 EN 61511-1:2004 EN 50156-1:2004 IEC 61131-2:2007 EN 50178:1997		EN 60204-1:2006 + A1:2009 (in extracts) NFPA 79:2007 NFPA 85:2007 NFPA 86:2007 ANSI B11.19:2003 ANSI/RIA R15.06:1999
Intended application	The devices comply with the requirements of the relevant standards (Cat. 4 / PL e acc. to EN ISO 13849-1, SIL CL 3 acc. to EN 62061 / IEC 61508) and can be used in applications up to Cat. 4 / PL e acc. to EN ISO 13849-1 and SIL 3 acc. to EN 62061 / IEC 61508.		
Specific requirements	The instructions of the associated Safety Reference Manual and User Manuals shall be considered.		
It is confirmed, that the product under test complies with the requirements for machines defined in Annex I of the EC Directive 2006/42/EC.			
This certificate is valid until 2015-12-08.			



The test report-no.: 968/EZ 191.11/10 dated 2010-12-08 is an integral part of this certificate.

The holder of a valid licence certificate for the product tested is authorized to affix the test mark shown opposite to products, which are identical with the product tested.




Berlin, 2010-12-08

Certification Body for Machinery, NB 0035