

**GuardLogix PLC**  
**Revision Release List**



**Rockwell Automation • Certificate No.: 968/EZ 191.03/07**

**SIL3 – certified - Components**

Catalog Number	Description / System	Series:	Firmware Revision	Report – No.	Certification Status
1756-L61S	Primary Controller (ControlLogix556xS) with 2 MB Memory	B	14.32 14.33 16.6 16.7 <sup>1</sup>	968/EZ 191.00/05 968/EZ 191.01/05 968/EZ 191.02/07 968/EZ 191.03/07	<i>Valid</i>
1756-L62S	Primary Controller (ControlLogix556xS) with 4 MB Memory	B	14.32 14.33 16.6 16.7 <sup>1</sup>	968/EZ 191.00/05 968/EZ 191.01/05 968/EZ 191.02/07 968/EZ 191.03/07	<i>Valid</i>
1756-LSP	GuardLogix Safety Partner (ControlLogix55SP)	B	14.32 14.33 16.6 16.7 <sup>1</sup>	968/EZ 191.00/05 968/EZ 191.01/05 968/EZ 191.02/07 968/EZ 191.03/07	<i>Valid</i>
1791DS-IB12	DeviceNet Safety Input Module	A	1.1	968/EZ 190.01/05	<i>Valid</i>
1791DS-IB8XOB8	DeviceNet Safety Input/Solid-State Output Module	A	1.1 1.2 <sup>1</sup>	968/EZ 190.02/05	<i>Valid</i>
1791DS-IB4XOW4	DeviceNet Safety Input/Relay	A	1.1	968/EZ 190.01/05	<i>Valid</i>
1791DS-IB8XOBV4	Guard I/O DeviceNet Safety Module	A	1.3	968/EZ 243.02/07	<i>Valid</i>
1732DS-IB8XOBV4	DeviceNet Safety Input/Output Module	A	1.3	968/EZ 243.02/07	<i>Valid</i>
1791DS-IB16	DeviceNet Safety Input Module	A	1.3	968/EZ 243.02/07	<i>Valid</i>

**GuardLogix PLC**  
**Revision Release List**



**Rockwell Automation • Certificate No.: 968/EZ 191.03/07**

**Further HW/SW Components suitable for use to build up safety loops up to SIL3 with GuardLogix:**

Catalog Number	Description / System	Series:	Firmware Revision	Report – No.	Status
1756-A4, A7, A10, A13 & A17	ControlLogix Chassis	B	NA	968/EZ 191.00/05	<i>Valid</i>
1756-PA75	AC Power supply	A, B	NA	968/EZ 191.00/05	<i>Valid</i>
1756-PB75	DC Power supply	A, B	NA	968/EZ 191.00/05	<i>Valid</i>
1756-PA75R	AC Redundant power supply	A	NA	968/EZ 191.00/05	<i>Valid</i>
1756-PB75R	DC Redundant power supply	A	NA	968/EZ 191.00/05	<i>Valid</i>
1756-PA72 AC	AC Power supply	C	NA	968/EZ 191.00/05	<i>Valid</i>
1756-PB72	DC Power supply	C	NA	968/EZ 191.00/05	<i>Valid</i>
1756-PSCA	Redundant Power Supply Chassis Adapter Module	A	NA	968/EZ 191.00/05	<i>Valid</i>
1756-PSCA2	Redundant Power Supply Chassis Adapter Module	A	NA	968/EZ 191.00/05	<i>Valid</i>
1756-ENBT	EtherNet Communication Module	A	3.6 4.3 <sup>1</sup>	968/EZ 191.02/07	<i>Valid</i>
1756-DNB	DeviceNet Communication Module	B	6.2 7.1 <sup>1</sup>	968/EZ 191.02/07	<i>Valid</i>

**GuardLogix PLC  
Revision Release List**



**Rockwell Automation • Certificate No.: 968/EZ 191.03/07**

*Further HW/SW interference free Components suitable for use to build up safety loops up to SIL2 with the standard task of GuardLogix:*

<b>Catalog Number</b>	<b>Description / System</b>	<b>Series:</b>	<b>Firmware Revision</b>	<b>Report – No.</b>	<b>Status</b>
1756-CN2	ControlNet Communication Module	A	12.1	968/EZ 191.02/07	<i>Valid</i>
1756-CN2R	Redundant ControlNet Communication Module	A	12.1	968/EZ 191.02/07	<i>Valid</i>